

Outlet Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Action	Passing/Clearance Results (in parts per billion; must be ≤ 5.0 parts per billion)	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2021-SO-CL-001	Cottage Lane ES	1	Classroom 411 Faucet	5/25/2021	1.5	Not Required	Not Required	1.5	Yes	5/25/2021	Not Applicable
2021-SO-CL-002	Cottage Lane ES	1	Classroom 410 Faucet	5/25/2021	1.3	Not Required	Not Required	1.3	Yes	5/25/2021	Not Applicable
2021-SO-CL-003	Cottage Lane ES	1	Classroom 409 Faucet	5/25/2021	1.7	Not Required	Not Required	1.7	Yes	5/25/2021	Not Applicable
2021-SO-CL-004	Cottage Lane ES	1	Classroom 408 faucet	5/25/2021	1.4	Not Required	Not Required	1.4	Yes	5/25/2021	Not Applicable
2021-SO-CL-005	Cottage Lane ES	1	Classroom 407 Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-006	Cottage Lane ES	1	Classroom 406 Faucet	5/25/2021	1.8	Not Required	Not Required	1.8	Yes	5/25/2021	Not Applicable
2021-SO-CL-007	Cottage Lane ES	1	Classroom 405 Faucet	5/25/2021	2.3	Not Required	Not Required	2.3	Yes	5/25/2021	Not Applicable
2021-SO-CL-008	Cottage Lane ES	1	Classroom 400 Faucet	5/25/2021	2.3	Not Required	Not Required	2.3	Yes	5/25/2021	Not Applicable
2021-SO-CL-009	Cottage Lane ES	1	Classroom 400 Fountain	5/25/2021	2.2	Not Required	Not Required	2.2	Yes	5/25/2021	Not Applicable
2021-SO-CL-010	Cottage Lane ES	1	Water Cooler Fountain Outside Room 400	5/25/2021	<1.0	Even though this unit passed, it was replaced with a new Bottle Filler Unit.	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-011	Cottage Lane ES	1	Water Cooler Fountain Outside Room 400 - Lower	5/25/2021	<1.0	Even though this unit passed, it was replaced with a new Bottle Filler Unit.	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-012	Cottage Lane ES	1	Classroom 102A Faucet	5/25/2021	1.8	Not Required	Not Required	1.8	Yes	5/25/2021	Not Applicable
2021-SO-CL-013	Cottage Lane ES	1	Classroom 102B Faucet	5/25/2021	2.3	Not Required	Not Required	2.3	Yes	5/25/2021	Not Applicable
2021-SO-CL-014	Cottage Lane ES	1	Classroom 107 Faucet	5/25/2021	2.5	Not Required	Not Required	2.5	Yes	5/25/2021	Not Applicable
2021-SO-CL-015	Cottage Lane ES	1	Classroom 108 Faucet	5/25/2021	3.1	Not Required	Not Required	3.1	Yes	5/25/2021	Not Applicable

2021-SO-CL-016	Cottage Lane ES	1	Classroom 109 Faucet	5/25/2021	5.2	DO NOT DRINK WATER sign installed; Aerator to be replaced then resampled	TBD	5.2	No	Pending	Not Applicable
2021-SO-CL-017	Cottage Lane ES	1	Classroom 110 Faucet	5/25/2021	3.1	Not Required	Not Required	3.1	Yes	5/25/2021	Not Applicable
2021-SO-CL-018	Cottage Lane ES	1	Classroom 111 Faucet	5/25/2021	5.9	DO NOT DRINK WATER sign installed; Aerator replaced; to be resampled	TBD	5.9	No	Pending	Not Applicable
2021-SO-CL-019	Cottage Lane ES	1	Hallway outside Classroom 107- Water Cooler (Combo Unit) - Mouth	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-020	Cottage Lane ES	1	Hallway outside Classroom 107- Water Cooler Combo Unit)- Bottle Filler	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-021	Cottage Lane ES	1	Room 101A (Book Room) Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-022	Cottage Lane ES	1	Kitchen- Single Faucet	5/25/2021	1.8	Not Required	Not Required	1.8	Yes	5/25/2021	Not Applicable
2021-SO-CL-023	Cottage Lane ES	1	Kitchen -Double faucet left (facing) - sink 1	5/25/2021	2.3	Not Required	Not Required	2.3	Yes	5/25/2021	Not Applicable
2021-SO-CL-024	Cottage Lane ES	1	Kitchen-Double faucet right - sink 2	5/25/2021	2.5	Not Required	Not Required	2.5	Yes	5/25/2021	Not Applicable
2021-SO-CL-025	Cottage Lane ES	1	Teacher's Lounge Faucet	5/25/2021	3.1	Not Required	Not Required	3.1	Yes	5/25/2021	Not Applicable
2021-SO-CL-026	Cottage Lane ES	1	Classroom 205 Faucet	5/25/2021	5.2	DO NOT DRINK WATER sign installed; Aerator to be replaced then resampled	TBD	5.2	No	Pending	Not Applicable
2021-SO-CL-027	Cottage Lane ES	1	Classroom 208 Faucet	5/25/2021	3.1	Not Required	Not Required	3.1	Yes	5/25/2021	Not Applicable
2021-SO-CL-028	Cottage Lane ES	1	Water Cooler Fountain Outside Classroom 300B	5/25/2021	5.9	Outlet rermantly removed from service.	Outlet rermantly removed from service.	Outlet rermantly removed from service.	Outlet rermantly removed from service.	Outlet rermantly removed from service.	Not Applicable
2021-SO-CL-029	Cottage Lane ES	1	Classroom 300C Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-030	Cottage Lane ES	1	Classroom 301B Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-031	Cottage Lane ES	1	Classroom 301A Faucet	5/25/2021	2.7	Not Required	Not Required	2.7	Yes	5/25/2021	Not Applicable

2021-SO-CL-048	Cottage Lane ES	1	Room 210 Hose Bib (in classroom)	5/25/2021	4.5	Not Required	Not Required	4.5	Yes	5/25/2021	Not Applicable
2021-SO-CL-049	Cottage Lane ES	Modular	Modular Library- Upper Water Cooler Fountain	5/25/2021	7.6	Outlet Permanently Removed from Service	Not Applicable				
2021-SO-CL-050	Cottage Lane ES	Modular	Modular Library- Water Cooler Fountain(Combo Unit) - Mouth	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-051	Cottage Lane ES	Modular	Modular Library- Water Cooler Fountain - (Combo Unit)- Bottle Filler	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-CL-095	Cottage Lane ES	1	Hallway outside Classroom 400- New Water Cooler (Combo Unit) - Mouth	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-CL-096	Cottage Lane ES	1	Hallway outside Classroom 400- New Water Cooler Combo Unit)- Bottle Filler	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-CL-097	Cottage Lane ES	1	Hallway outside Classroom 300B- New Water Cooler (Combo Unit) - Mouth	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-CL-098	Cottage Lane ES	1	Hallway outside Classroom 300B- New Water Cooler Combo Unit)- Bottle Filler	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-CL-099	Cottage Lane ES	1	Hallway outside Classroom 303 (by Girls Bathroom)- New Water Cooler Combo Unit)- Mouth	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-CL-100	Cottage Lane ES	1	Hallway outside Classroom 303 (by Girls Bathroom)- New Water Cooler Combo Unit)- Bottle Filler	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-CL-101	Cottage Lane ES	1	Hallway outside Classroom 303 (by Boys Bathroom)- Water Cooler Combo Unit)- Mouth	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-CL-102	Cottage Lane ES	1	Hallway outside Classroom 303 (by Boys Bathroom)- New Water Cooler Combo Unit)- Bottle Filler	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
Non-Applicable Outlets Below (these are outlets that were determined by the District to not be used for cooking or drinking by staff or students.											
2021-SO-CL-052	Cottage Lane ES	1	Custodial Closet in 100s Wing - Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
2021-SO-CL-053	Cottage Lane ES	1	Custodial Closet Across from Room 206- Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.
2021-SO-CL-054	Cottage Lane ES	1	Boiler Room Slop Sink	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.

2021-SO-CL-071	Cottage Lane ES	1	Gender Neutral bathroom faucet across from classroom 205	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-072	Cottage Lane ES	1	Nurses Office (Rm 201)- bathroom faucet	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-073	Cottage Lane ES	1	Teachers bathroom faucet across from classroom 301	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-074	Cottage Lane ES	1	Girls bathroom outside of classroom 300B left sink (facing) faucet 1	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-075	Cottage Lane ES	1	Girls bathroom outside of classroom 300B right sink (facing) faucet 2	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-076	Cottage Lane ES	1	Boys bathroom outside of classroom 300B	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-077	Cottage Lane ES	1	Girls bathroom across from classroom 303 left (facing) sink faucet 1	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-078	Cottage Lane ES	1	Girls bathroom across from classroom 303 middle sink faucet 2	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-079	Cottage Lane ES	1	Girls bathroom across from classroom 303 right sink faucet 3	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-080	Cottage Lane ES	1	Boys bathroom across from classroom 303 left sink (facing) faucet 1	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-081	Cottage Lane ES	1	Boys bathroom across from classroom 303 middle sink faucet 2	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-082	Cottage Lane ES	1	Boys bathroom across from classroom 303 right sink faucet 3	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-083	Cottage Lane ES	1	Gender Neutral Bathroom Faucet Across from classroom 105	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-084	Cottage Lane ES	1	Gender Neutral Bathroom Faucet Next to classroom 102C	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-085	Cottage Lane ES	1	Girls Bathroom Across from classroom 400 left sink (facing) faucet 1	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-CL-086	Cottage Lane ES	1	Girls Bathroom Across from classroom 400 middle sink faucet 2	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						

