

Outlet Number	School	Floor	Location/Classroom #	First Sample Date	First Sample Results (in parts per billion)	Remediation Action -- Required for any Outlet > 5.0 parts per billion	Resampling Dates -- Required After Remediation Action	Passing/Clearance Results; must be ≤ 5.0 parts per billion	Is Outlet in Compliance?	Passing/Clearance Date	Reason why Outlet was NOT Sampled & Actions Taken to Prevent Consumption
2021-SO-WS-001	Wm O'Schaefer	1	Classroom 1 Faucet	5/25/2021	1.7	Not Required	Not Required	1.7	Yes	5/25/2021	Not Applicable
2021-SO-WS-002	Wm O'Schaefer	1	Classroom 2 Faucet	5/25/2021	1.5	Not Required	Not Required	1.5	Yes	5/25/2021	Not Applicable
2021-SO-WS-003	Wm O'Schaefer	1	Classroom 3 (Tech. Office) Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-004	Wm O'Schaefer	1	Classroom 4 Faucet	5/25/2021	3.1	Not Required	Not Required	3.1	Yes	5/25/2021	Not Applicable
2021-SO-WS-005	Wm O'Schaefer	1	Classroom 6 Faucet	5/25/2021	1.0	Not Required	Not Required	1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-006	Wm O'Schaefer	1	Nurse's Office (Main Room) Faucet	5/25/2021	1.6	Not Required	Not Required	1.6	Yes	5/25/2021	Not Applicable
2021-SO-WS-007	Wm O'Schaefer	1	Nurse's Office Recovery Room Faucet	5/25/2021	3.0	Not Required	Not Required	3.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-008	Wm O'Schaefer	1	Classroom 15 Faucet	5/25/2021	1.2	Not Required	Not Required	1.2	Yes	5/25/2021	Not Applicable
2021-SO-WS-009	Wm O'Schaefer	1	Classroom 17 Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-010	Wm O'Schaefer	1	Classroom 17 Fountain	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-011	Wm O'Schaefer	1	Classroom 19 Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-012	Wm O'Schaefer	1	Classroom 21 Faucet	5/25/2021	1.0	Not Required	Not Required	1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-013	Wm O'Schaefer	1	Classroom 24 Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-014	Wm O'Schaefer	1	Classroom 24 Fountain	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-015	Wm O'Schaefer	1	Classroom 26 Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-016	Wm O'Schaefer	1	Classroom 26 Fountain	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-017	Wm O'Schaefer	1	Classroom 30 Faucet	5/25/2021	1.3	Not Required	Not Required	1.3	Yes	5/25/2021	Not Applicable
2021-SO-WS-018	Wm O'Schaefer	1	Classroom 32 Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-019	Wm O'Schaefer	1	Classroom 32 Fountain	5/25/2021	1.4	Not Required	Not Required	1.4	Yes	5/25/2021	Not Applicable
2021-SO-WS-020	Wm O'Schaefer	1	Teacher's Lounge (Room 37) Faucet	5/25/2021	1.9	Not Required	Not Required	1.9	Yes	5/25/2021	Not Applicable
2021-SO-WS-021	Wm O'Schaefer		Kitchen - Double Sink/Faucet 1 (left when facing)	5/25/2021	2.3	Not Required	Not Required	2.3	Yes	5/25/2021	Not Applicable
2021-SO-WS-022	Wm O'Schaefer	1	Kitchen - Double Sink/Faucet 2 (right when facing)	5/25/2021	1.5	Not Required	Not Required	1.5	Yes	5/25/2021	Not Applicable
2021-SO-WS-023	Wm O'Schaefer	1	Small/Single Kitchen Sink Faucet	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-024	Wm O'Schaefer	1	Hallway Across from Room 40- Water Cooler Fountain (Combo Unit) - Mouth	6/22/2021	1.8	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-025	Wm O'Schaefer	1	Hallway Across from Room 40- Water Cooler Fountain (Combo Unit) - Bottle Filler	5/25/2021	<1.0	Not Required	Not Required	<1.0	Yes	5/25/2021	Not Applicable
2021-SO-WS-026	Wm O'Schaefer	1	Classroom 44 faucet	6/22/2021	12.0	DO NOT Drink Sign Installed; Aerator to be changed then resampled	TBD	12.0	No	6/22/21	Not Applicable
2021-SO-WS-027	Wm O'Schaefer	1	Hallway by Room 56- Water Cooler (Combo Unit) - Mouth	6/22/2021	<1.0	Not Required	Not Required	<1.0	Yes	6/22/21	Not Applicable



2021-SO-WS-087	Wm O'Schaefer	1	New Water Cooler Fountain (West) by <b>Hallway Outside Kitchen</b> (Mouth) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-088	Wm O'Schaefer	1	New Water Cooler Fountain (West) by <b>Hallway Outside Kitchen</b> (Mouth) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-089	Wm O'Schaefer	1	New Water Cooler Fountain by <b>New Girls Room across from Room 57</b> (Mouth) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-090	Wm O'Schaefer	1	New Water Cooler Fountain by <b>New Girls Room across from Room 57</b> (Bottle Filler) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-091	Wm O'Schaefer	1	New Water Cooler Fountain by <b>New Boys Room across from Room 57</b> (Mouth) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-092	Wm O'Schaefer	1	New Water Cooler Fountain by <b>New Boys Room across from Room 57</b> (Bottle Filler) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-093	Wm O'Schaefer	1	New Water Cooler Fountain by <b>New Girls Room next to Room 70</b> (Mouth) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-094	Wm O'Schaefer	1	New Water Cooler Fountain by <b>New Girls Room next to Room 70</b> (Bottle Filler) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-095	Wm O'Schaefer	1	New Water Cooler Fountain by <b>New Boys Room next to Room 69</b> (Mouth) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable
2021-SO-WS-096	Wm O'Schaefer	1	New Water Cooler Fountain by <b>New Boys Room next to Room 69</b> (Bottle Filler) Combo Unit-	TBD	Pending	Pending	Pending	Pending	Pending	Pending	Not Applicable

**Non-Applicable Outlets Below (these are outlets that were determined by the District to not be used for cooking or drinking by staff or students.)**

2021-SO-WS-055	Wm O'Schaefer	1	Gender Neutral Staff bathroom across from Room 103 - faucet	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-056	Wm O'Schaefer	1	Classroom 105 (OT/PT Rm) Bathroom Faucet	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-057	Wm O'Schaefer	1	Coach Office (in Gym) Bathroom Faucet	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-058	Wm O'Schaefer	1	Boys Bathroom Outside Rooms 67/69 -- Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-059	Wm O'Schaefer	1	Boys Bathroom Outside Rooms 67/69 -- Faucet 2 (left when facing)	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-060	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 -- Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-061	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 -- Faucet 2 (middle when facing)	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-062	Wm O'Schaefer	1	Girls Bathroom Outside Rooms 70/72 -- Faucet 1 (right when facing)	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-063	Wm O'Schaefer	1	Student Enrichment (Room 20 B) (across hallway from Main Office) bathroom faucet	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-064	Wm O'Schaefer	1	Outside Room 56- Boy's Bathroom Faucet 1 (left when facing)	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						
2021-SO-WS-065	Wm O'Schaefer	1	Outside Room 56- Boy's Bathroom Faucet 2 (right when facing)	<i>Not Sampled</i>	<i>Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.</i>						

2021-SO-WS-066	Wm O'Schaefer	1	Outside Rm 54 girl's bathroom faucet 1 (left when facing)	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-067	Wm O'Schaefer	1	Outside Rm 54 girl's bathroom faucet 2 (left when facing)	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-068	Wm O'Schaefer	1	Custodial Office Bathroom Faucet	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-069	Wm O'Schaefer	1	Next to Room 40 Gender Neutral bathroom faucet 1 (left when facing)	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-070	Wm O'Schaefer	1	Next to Room 40 Gender Neutral bathroom faucet 2 (right when facing)	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-071	Wm O'Schaefer	1	Nurse's Office Bathroom Faucet	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-072	Wm O'Schaefer	1	Custodial Closet by Room 60 Slop Faucet	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-073	Wm O'Schaefer	1	Boys bathroom between Rooms 6 and 16 - tempered faucet to the left when facing	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-074	Wm O'Schaefer	1	Boys bathroom between Rooms 6 and 16 - tempered faucet to the right when facing	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-075	Wm O'Schaefer	1	Girls bathroom between Rooms 6 and 16 - tempered faucet to the left when facing	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-076	Wm O'Schaefer	1	Boiler Room Faucet	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-077	Wm O'Schaefer	1	Girls bathroom between Rooms 6 and 16 - tempered faucet to the right when facing	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-078	Wm O'Schaefer	1	Custodial Closet Across from Library- Slop Sink	Not Sampled	Outlet classified as "non applicable". DO NOT DRINK signage displayed; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-079	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall to left of Main Entrance	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-080	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall to right of Main Entrance	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-081	Wm O'Schaefer	Exterior	Exterior Hose Bib- by Staff Parking lot/South Playground	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-082	Wm O'Schaefer	Exterior	Exterior Hose Bib- wall by South playground	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-083	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall outside Room 68	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.						
2021-SO-WS-084	Wm O'Schaefer	Exterior	Exterior Hose Bib- Wall outside Room 100	Not Sampled	Outlet classified as "non applicable". Special tool needed to access; ongoing education provided to staff and students to not consume water from this type of outlet.						
This spreadsheet was last updated on 7-25-23											